WATER BUME

MISSISSIPPI STATE DEPARTM BUREAU OF PUBLIC WAT	ENT OF HEALTH JUL 27 AM 8: 56 ER SUPPLY
MISSISSIPPI STATE DEPARTMI BUREAU OF PUBLIC WAT CCR CERTIFICATIO CALENDAR YEAR 20 Public Water Supply No	old ASSn. TNC.
List PWS ID #s for all Community Water Syst	tems included in this CCR
The Federal Safe Drinking Water Act (SDWA) requires each Commun Consumer Confidence Report (CCR) to its customers each year. Dependent of the CCR must be mailed or delivered to the customers, published customers upon request. Make sure you follow the proper procedures we mail a copy of the CCR and Certification to MSDH. Please check all	inity public water system to develop and distribute a ending on the population served by the public water in a newspaper of local circulation, or provided to the when distributing the CCR. You must mail, fax or boxes that apply.
Customers were informed of availability of CCR by: (Attach of	
□ Advertisement in local paper (attach copy of Date(s) customers were informed: □ 1000 paper (attach copy of Date(s) Customers were informed: □ 1000 paper (attach copy of Date(s) custom	of advertisement) to the address below) Duthwhen fassing Out Bills
Date(s) customers were informed: <u>OJOL/15</u> , <u>O7/0</u>	2115, 1 1
CCR was distributed by U.S. Postal Service or other diremethods used	ct delivery. Must specify other direct delivery
Date Mailed/Distributed: / /	
CCR was distributed by Email (MUST Email MSDH a copy) As a URL (Provide URL As an attachment As text within the body of the email message	
CCR was published in local newspaper. (Attach copy of publis	
Name of Newspaper:	
Date Published:/	
CCR was posted in public places. (Attach list of locations)	Date Posted: <u>07</u> / <u>03</u> / 15
CCR was posted on a publicly accessible internet site at the fol	
CERTIFICATION I hereby certify that the 2014 Consumer Confidence Report (CCR public water system in the form and manner identified above and the SDWA. I further certify that the information included in this the water quality monitoring data provided to the public water Department of Health, Bureau of Public Water Supply. **Dalla Selection** Name/Title (President, Mayor, Owner, etc.)	d that I used distribution methods allowed by CCR is true and correct and is consistent with
	, yuie
Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700	May be faxed to: (601)576-7800
Jackson, MS 39215	May be emailed to: water.reports@msdh.ms.gov

Copy of 2014 Annual Drinking Water Quality Report Winterville Water Assoc. PWS 0760010

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 21 of those contaminants, and found only 1 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is from a well, drawing from the Cockfield Formation Aquifier.

Source water assessment and its availability

Our source water assessment has been completed. Our well was ranked lower in terms of susceptibility to contamination. For a copy of the report, please contact our office at 601-576-7518.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Our Board meets on the first Monday each month at 6:00 pm at the Myrtle Grove MB Church, Winterville, MS. We welcome and encourage all customers who have concerns or questions to attend these meetings.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit <u>www.epa.gov/watersense</u> for more information.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Winterville Water Assoc. PWS 0760010 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG	MCL,							
	or	TT, or	Your	1 1	nge	Sample			
<u>Contaminants</u>	MRDLG	MRDL	Water	Low	<u>High</u>	<u>Date</u>	<u>Violation</u>	Typical Source	
<u> </u>	Disinfectants & Disinfectant By-Products								
	evidence th	at additic	n of a di	sinfect	ant is n	ecessary	for control c	of microbial contaminants)	
Chlorine (as Cl2) (ppm)	4	4	1.01	0.06	1.4	2014	No	Water additive used to control microbes	
TTHMs [Total Trihalomethanes] (ppb)	NA	80	28.7	NA		2013	No	By-product of drinking water disinfection	
Haloacetic Acids (HAA5) (ppb)	NA	60	21	NA		2013	No	By-product of drinking water chlorination	
Inorganic Contamina	ants								
Cyanide [as Free Cn] (ppb)	200	200	15	NA		2013	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories	
Antimony (ppb)	6	6	0.5	NA		2013	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.	
Arsenic (ppb)	0	10	0.5	NA		2013	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Barium (ppm)	2	2	0.004	NA		2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Beryllium (ppb)	4	4	0.5	NA		2013	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries	
Cadmium (ppb)	5	5	0.5	NA		2013	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints	

Chromium (ppb)	100	100	2.3	NA		2013		No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.296	NA		2013	-	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.5	NA		2013		No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	0.0025	NA		2013]	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2013]	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0.08	NA		2014]	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2014]	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radioactive Contam	inants				i je ilij		Sile		
Alpha emitters (pCi/L)	0	15	3	NA		2012	1	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.067	NA		2013]	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	0.696	NA		2013	1	No	Erosion of natural deposits
<u>Contaminants</u>	<u>MCLG</u>	AL	Your <u>Water</u>	Samp <u>Date</u>		# Sample Exceeding A	. 1	Excee AL	ds Typical Source
Inorganic Contamin	ants								
Copper - action level at consumer taps (ppm)	1.3	1.3	2.6	2014	1	2		Yes	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0.015	2014	1	0		No	Corrosion of household plumbing systems; Erosion of natural deposits

Violations and Exceedances

Copper - action level at consumer taps

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor. 2014 Reported results of samples to sample site customers. The two sample site customers over the limit were instructed to run the water a minute before using the water to drink or cook with and only use cold water to drink or cook with.

Term	Definition				
ug/L	ug/L: Number of micrograms of substance in one liter of wate				
ppm	ppm: parts per million, or milligrams per liter (mg/L)				
ppb	ppb: parts per billion, or micrograms per liter (μg/L)				
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)				
NA	NA: not applicable				
ND	ND: Not detected				
NR	NR: Monitoring not required, but recommended.				

mportant Drinking Water Definitions					
Term	Definition				
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.				
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.				
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.				
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.				
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.				
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.				
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.				
MNR	MNR: Monitored Not Regulated				
MPL	MPL: State Assigned Maximum Permissible Level				

TT Violation	Explanation	Length	Steps Taken to Correct the	Health Effects Language
1. 1.			<u>Violation</u>	

Lead and copper rule	Two Sample sites	2014	Reported sample	Copper is an essential
violations	tested over limit.		results to two	nutrient, but some people
			customers over the	who drink water containing
			limit. They were	copper in excess of the
			instructed to run the	action level over a relatively
			water a minute	short amount of time could
			before using the	experience gastrointestinal
			water to drink or to	distress. Some people who
			cook with and only	drink water containing
			use cold water for	copper in excess of the
			drinking or cooking.	action level over many
				years could suffer liver or
				kidney damage. People with
				Wilson's Disease should
				consult their personal
				doctor.

For more information please contact:

Contact Name: Aaron Nicholson

Address: 2136 Carol St

Greenville, MS 38703 Phone: 662-822-5132

E-Mail: apnicholson@suddenlink.net

MAIER SUPPLY

2015 JUL 27 AM 8: 55

fulle places:

1. Bulletin Land at the Fost Alexan.

2. John Hill's Bleve

3. Gulletin Board at Mystle Aroue Missionary Bastest Churc. 11 44 Blayfork Gd. Winterield, MS. 38783